

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer
 Company
 Address

 Post Code
 Tel No.
 Gas Safe Reg
 ID Card No.

Job Address

Name
 Address

 Post Code
 Tel. No

Customer / Landlord

Name
 Company
 Address

 Post Code
 Tel. No

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Kitchen	Boiler	Worcester	Greenstar 25i	RS	Yes	Yes	21	23.57	33	8	9.6	NA	NA	NA	Yes	Yes	Yes	Pass	Yes	Yes
2	Kitchen	Hob	Bosch	4 Ring	FL	Yes	Yes	21	6.40	NA	NA	NA	NA	NA	NA	Yes	Yes	NA	NA	No	Yes
3																					
4																					
5																					
6																					

Defects / Identified

Labels and Warning Notice Issued

CO Alarm(s)

Smoke Alarm(s)

1		No
2		No
3		
4		
5		
6		

CO Alarm(s) fitted	Yes	Smoke Alarm(s) fitted	Yes
CO Alarm(s) tested and Satisfactory	Pass	Smoke Alarm(s) tested and Satisfactory	Pass

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes


Gas Installation Pipework Visual Inspection Satisfactory Yes

Number of Appliances Tested Equipotential Bonding Yes

NEXT INSPECTION DUE ON OR BEFORE

Comments

Signatures

Issued by: Signed 
 Print Name

Received Signed by:
 Print Name

Date